

Tel. 997-9451

Jay Jones

11/6/89

700 Acushnet Ave.

New Bedford, Ma 02740

#31448 E.S. #700 Acushnet Ave.

Please install 8" CLCI (fire supply) to supply a comm.
bldg. from Acushnet Ave. Replaces 6" ser. #29600 to be
discontinued. 72

Measures of 8" gate valve:

N x N line Pearl St .

563.0 ft.

W x E line Acushnet Ave.

8.2 ft.

N x S line Bldg.

5.0 ft.

N x old Seneca S t. gate

17.7 ft.

S x 2" gate box

2.0 ft.

Main to 8" gate (east)

12.0 ft.

Main is 20 ft. W x E line.

Work done Dec. 1989

Tapped, dig & installed by J. Hoadley & Sons
1 - 30" x 8" Mueller tapp. sleeve, poured lead
1 - 8" Mueller tapping gate - buried under gas main
No box - 9.5 ft. W x 8" east gate.
1 - 8" Mueller gate valve (on sidewalk)
9.5 ft. - 8" pipe between gates.
Note: All fittings rodded and friction clamps used.

See attached sketch for Installation of Smith private hydrant.

Insp.....	\$	15.00
Turn on charge.....	\$	25.00
	\$	40.00

Permit # 854

Plumbers Supply
Addittional Measures

Dec. 15, 1989

6" Fire Supply - # 31448 - 8" - 6"

E x W line Bldg. 7.0 ft.

S x S line Bldg. 7.5 ft.

6" Hydrant gate valve:

S x S line Bldg. 10.0 ft.

E x W line Bldg. 11.0 ft.

N.E. x hydrant 24.0 ft.

4 5/8" Smith Q.B. Hydrant, Mech. PRIVATE

S x S line Bldg. 26.5 ft.

W x W line Bldg. 7.0 ft.

S.W. x gate 24.0 ft.



NEW BEDFORD
WATER DEPARTMENT

NEW SERVICE



DATE Dec-1989

NUMBER 314 48

SIZE 8" 806"

NAME JAY JONES

STREET 68 ACUSH AVE

NUMBERS SUPPLY

AT OLD SENECA ST

AMT.

COST

AMT. COST

	TAP		TAP SLEEVE		
	STOP		TAP GATE		
	CURB BOX		BELL GATE		
	PIPE USED		GATE BOX		
	TEES		LEAD		
	CROSSES		LEADITE		
	COUPLING		JUTE		
	UNION		MISC		
	ELBOWS				
	ADAPTERS				
	COCKING CONNECTION		TAPPING MACHINE		
	MISC		STREET CUT TYPE		
			SIDEWALK CUT TYPE		
	METER CONNECTIONS		INSIDE DIGGING		
	LBS. SOLDER		HOLE IN WALL		
	SHOVEL		SCOOP		
	COMPRESSOR		PUMP		
	CARTING		STREET OPENING CHARGE		
	GENERATOR		FITTINGS		
	LABOR				
	SUPERVISION		PIPE STRAP		

NEAREST STREET TO BOX

CORNER BUILDING TO BOX

PROPERTY LINE TO BOX

MAIN TO LINE

PIPE INSIDE PROPERTY

HOUSE TO BOX

MEASUREMENTS OF DUCTS OR CABLES

FOREMAN

Joseph Rodriguez

Dec-16/1989

ALL WORK FRICTION CLAMPED
4180 ROPPED 5R

4480 ROPPED JR

Acush. Ave.

BURIED GATE

~~Dist + Dist~~

fast

84 GATE

2.0 PART

8x8x6TEE (ANGHOR)

SMITH HYDRAUT

ANCHOR - 8X8X6TEE

E.S. MECA Pkg.

SEAS. TIED TO

EXISTING YEARS

8
FULL LENGTHS 8 FROM 8" 5/4WK GATE
8x8" SPLIT HANGE TEE (4" 5/4WK 8) 6" GATE
8

28.3.30 PE. 8" DUCTILE, 1-8X8X6 1/2" FLANGE Tee
FOR HYDRANT ES MECHANICAL FLUG. 2.5" ID
6" MILLER GATE (HP) 2.5 PE 6" PIPE, 6" DIA.
45.5" 16.0 PE 6" PIPE + 5.5 PE 6" DUCTILE TO

45'-sw. 16.0 Pa cu PIPE + 5.5 Pa cu DUCTILE TO

NEW SMITH ACADEMY.

LIME TESTED BY J. HODLEY & SONS ON
"9-15-89-150 P.S.I. FOR ONE HOUR OR

1380 & TESTED 4/240 & HYDRANT TO

5/20/2008

30" WATER MAIN

140 GAS MTR IN

BUILDING

~~Phonics Supply~~

John D. Jones

