

6/26/90

Jeff A White
by Michael Dakin

2100 Realty Inc.
2100 Acushnet Ave.
New Bedford, Ma 02745

#31502 E.S. #2108 Acushnet Ave.

Please install 6" ductile (fire supply) to supply a
welfare bldg. from Harwich St. Sumner & Dunbar to tap. 119

Measure of 6" U.S. tapping gate valve, mech.:

E x E line Acushnet Ave. 248.0 ft.

N x S line Harwich St. 15.0 ft.

Work done July 10 & 14, 1990

Inspection charge was sent on Misc. Bill 8/1/90
to D.W. White Const. (\$ 120.69)

Turn on charge.....\$ 25.00

Sumner & Dunbar, Inc. tapped 8" Harwich St. main
with mechanical 8" x 8" x 6" U.S. tapping sleeve
6" U.S. Mech. tapping gate valve

150 ft. - 6" ductile pipe

1 - 6" 90° Bend, mech. east

30.0 ft. - 6" ductile pipe

1 - 6" 90° Bend, mech. south

17 ft. - 6" ductile pipe into bldg. (14 ft. to outside
wall)

Main on SS Harwich St. - 12 ft. W x east prop. line.
at SW cor. prop. - 14 ft. W x east prop. line.

6" water also crosses under tele. & elect., gas & 1½"
water & over drain & sewer on east & west 30.0 ft. pc.
pipe between bends north of bldg.

NOTE: No inspection done on main from about 20.0 ft. .
north x west bend to inside bldg., J. Rodrigues

Work done July 10 & 14, 1990

6" Fire Supply Ser. # 31502

