

Tel. #996-3333 Wash-rite Laundry P.O.Box 13043  
11/7/90 (Mark Bodzioch) N.B.,MA 02746

#31525 E.S. Milford St. S x Carlisle St. *113*  
Please install 4" Fire Supply to supply laundry. from  
Milford St. To be billed on Serv. #21582.

Measures of 4" Tapping Gate Valve:

S x S line Carlisle S t.	169.0 f t.
E x W line Milford St.	19.0 f t.
S x N line <del>house</del> Bldg.	61.6 ft.
N x S line <del>house</del> Bldg.	0.5 ft.
W x W line bldg.	46.0 f t.

Main is 18 ft. E x W line.  
Work done Nov. 15, 1990

Contractor supplied & installed all stock:

6" x 6" x 4" Tapping sleeve, mech.

1 - 4" Tapping gate valve, Mech.

#10 Roadway Gate Box, compl.

Riani Co. tapped service.

Wm. Smith dug, backfilled & will maintain trench.

Insp.....	\$ 15.00
Turn on charge.....	\$ 25.00
	<hr/>
	\$ 40.00