

Tel. 990-1920

Dick Corporation

P.O. Box 970

3/5/93

by Thomas Uram

N.B., Ma 02741

#31699 W.S. Service Rd. Wastewater Tr. Plant

(E. Rodney Fr. Blvd.) *Fort Rodman*

Please install a 2" copper service to supply 4 construction trailers. Meter in pit at access rd.

Measures of 2" Curb Stop:

S x S line Rodney French Blvd. (s) 779.0 ft.

N x S line trailer 18.5 ft.

S x N line trailer 34.5 ft.

W x meter pit 7.0 ft.

E x E line trailer 103.4 ft.

Main to curb stop 34.5 ft.

Work done March 19, 1993

This service is tapped off F .S. #28808

34.5 ft. - 2" Copper tubing @ 7.15'	246.68
2" Corporation tap.....	54.00
2" Curb Stop.....	82.00
1 Gate Box, compl.....	50.00
Carting.....	15.00
D-4 Drilling machine use.....	35.00
8" x 2" D.S. Serv. Saddle	27.00
2 - 2" meter flanges.....	28.00
Turn on charge.....	15.00
Labor.....	69.78
	<hr/>
	622.46

Service Reactivated
Fort Taber - Yacht Club

April 27, 2001
Ser. # 31699 1½"

- Former trailer 2" service extended to supply Yacht Club. Merak Const. installed 1 1½" copper service from existing meter pit. Cont. removed all 2" fittings from pit. Installed 2" x 1½" reducer bushing on existing 2" service in pit, 5 ft W x 2" curb stop. Cont. installed 1½" copper from pit into new addition on N.S. of bldg. Pit to be filled with sand.

Measures of existing 2" Curb stop:

N x N line transformer pad	8.6 ft.
N x N line Bldg.	38.7 ft.
E x E line Bldg.	28.5 ft.
W x e line Bldg.	14.3 ft.

M. Rose Insp

