

116

Coyne Laundry

5/14/93

31718 Howard Ave. E of Belleville Rd.

Please install a 4" copper ser. to supply a laundry . Replaces 6" ser.21840 to be discontinued. Has sewer.

Measures of 6" Gate Valve:

E x E line River R d.	171.5 ft.
N x N line bldg.	21.0 f t.
E x W line bldg.	41.0 ft.

Work done May 8, 1993

Canessa Const. supplied & installed all stock:

16.4 ft. - 6" ductile pipe

1 - 6" x 6" x 6" Anchor tee, mech.

1 - 6" Mueller gate valve, mech.

1 - 6" Rockwell #441 cast cplg. - tied into existing 6" service.

Inspection.....	\$ 15.00
Turn on charge.....	\$ 25.00
	<hr/>
	\$ 40.00