

Coyne Laundry P.O. Box 50148
3/25/94 New Bedford, 02745

#31828 S.S. Howard Ave. E x River Rd.

Please install a 8" ductile (fire supply) ser. to supply
a laundry plant. from Howard Ave. Bill on acct. #31718

Measures of 8" Mu. Tapping Gate Valve:

W x E line River Rd. 29.5 ft.

N x S line Howard Ave. 16.0 ft.

Work done Feb.18 & 22, 1994

J. Hoadley & Son installed 8" x 8" x 8" Mu. tapping sleeve & 8" Mu. tapping gate valve.

Nelson Cardoso supplied & installed all stock.
See main pipe report.

Inspection (2 days).....	\$ 30.00
O.T. 2/22/94 2 hrs. @ 1½.....	\$ 46.56
Turn on charge.....	<u>\$ 25.00</u>
	\$ 101.56