

Tel. 997-7411

7/12/94

Standard-Times

by James Knox

6 Market St.

N.B., Ma 02740

#31854 N.S. Elm St. E x Acushnet Ave.

53

Please install a 8"CLCI (fire supply) to supply the
Standard-Times bldg. from Elm St. Bill on ser. #31853

Measures of 8" Smith gate valve, mech:

E x E line No. Second St. 45.0 ft.

N x S line Elm St. 18.0 ft.

E x E line park. garage 49.0 ft.

S x S line park. garage 31.5 ft.

Main is 36 ft. S x N line.

Work done Aug. 8-11, 1975 main to prop. line

Oct. 1994 prop line to bldg.

✓

Federico Const. during West End Urban renewal
installed this service from the main to the prop. line
on Aug. 8-11, 1975 (future service) No bldg. at this time

Federico supplied & installed all stock:

40.4 ft. - 8" ductile pipe

1 - 16" x 16" x 8" CIGL Class 2 Tee, Mech. Jt.

8" Smith gate valve, mech. jt.

1 Buffalo gate box, compl.

Insp.....\$ 15.00

Turn on charge.....\$ 25.00

\$ 40.00

NOTE: This service was not inspected from the
property line to the bldg.