

Tel. (401) 457-3331  
11/30/95

Department of Veterans Affairs  
830 Chalkstone Ave. Providence, RI

#31964 #175 Elm St.

Please install a 6" CLCI ser. (fire supply) to supply a  
veterans out-patient clinic (the old Blue Cross bldg)  
from Elm St. Billed on acct. #29966

Measures of 6" Mueller Achor Gate Valve, Mech:

|                        |          |
|------------------------|----------|
| E x E line Eighth S t. | 38.8 ft. |
| N x S line Elm St.     | 16.4 ft. |

Work done Dec. 7, 1995

J

J. Hoadley & Sons, Inc. made tap & installed:  
8" x 8" x 6" Tapping Sleeve  
6" Mueller Anchor Gate Valve  
#10 Gate Box, compl.

|                     |                 |
|---------------------|-----------------|
| Inspection.....     | \$ 15.00        |
| Turn on Charge..... | <u>\$ 25.00</u> |
|                     | \$ 40.00        |

Nelson Cardoso Permit # 402

NEW BEDFORD  
WATER DEPARTMENT

NEW SERVICE



*\* 31964*

DATE 12-7-95

NUMBER Fire supply SIZE 6" DI

NAME CARDOSO CONTRACTOR

STREET 175 Elm ST

Note: Contractor supply all material 8" x 6" TAPPING SLEEVE with 6" ANCHOR TEE GATE VALVE MURDER #10 G. BOX

| AMT. | COST               | AMT. | COST                            |
|------|--------------------|------|---------------------------------|
|      | TAP                |      | TAP SLEEVE                      |
|      | STOP               |      | TAP GATE                        |
|      | CURB BOX           |      | BELL GATE                       |
|      | PIPE USED          |      | GATE BOX                        |
|      | TEES               |      | LEAD                            |
|      | CROSSES            |      | LEADITE                         |
|      | COUPLING           |      | JUTE <i>Out Patient Clinic</i>  |
|      | UNION              |      | MISC <i>175 Elm St.</i>         |
|      | ELBOWS             |      |                                 |
|      | ADAPTERS           |      |                                 |
|      | COCKING CONNECTION |      | TAPPING MACHINE                 |
|      | MISC               |      | STREET CUT TYPE                 |
|      |                    |      | SIDEWALK CUT TYPE               |
|      | METER CONNECTIONS  |      | INSIDE DIGGING <i>Nepon</i>     |
|      | LBS. SOLDER        |      | HOLE IN WALL <i>Cardoso</i>     |
|      | SHOVEL             |      | SCOOP <i>#402</i>               |
|      | COMPRESSOR         |      | PUMP                            |
|      | CARTING            |      | STREET OPENING CHARGE           |
|      | GENERATOR          |      | FITTINGS <i>2x United Stone</i> |
|      | LABOR              |      | <i>request T.O. 2/23/96</i>     |
|      | SUPERVISION        |      | PIPE STRAP                      |

MEASURES 6" GATE VALVE

NEAREST STREET TO BOX EXE LINE EIGHT ST 38.8 ft

CORNER BUILDING TO BOX

PROPERTY LINE TO BOX NXSLINE ELM ST. 16.4 ft

MAIN TO LINE

PIPE INSIDE PROPERTY

HOUSE TO BOX

MEASUREMENTS OF DUCTS OR CABLES


6" LINE TO BE PRESSURE TESTED

AND CHECKED By D.E.P.

FOREMAN

F. Bento

TAPPING MAIN (WET TAP) MADE BY: JOHN HOADLEY AND SONS, INC.



#175 ELM ST  
V.A. CLINIC

JAN. 25-96

Note: ARAUJO PLUMBER

PRESSURE TESTED 6" FIRE SUPPLY

150 PSI TIME 1 HOUR 50 MINUTES

O.K.

INSPECTED F.B.

ELM ST

8" main