

City of New Bedford

by William Andrade d/b/a Bill Andrade & Son, Inc.

#32131 E.S. So. Sixth St. S x William St. 52

Please install a 6" CLCI (fire supply) to supply a library. from So. Sixth St. Sumner & Dunbar to tap

Measures of 6" Gate Valve:

S x S line William S t.	42.0 ft.
W x E line So. Sixth S t.	35.0 ft.
S x N line house	27.0 ft.
N x S line house	65.0 ft.
W x W line Bldg.	45.0 f t.

Main is 14 ft. E x W line.

Work done Dec. 29, 1997

private gate hook - ok

Stock supplied by Contractor Andrade & Son

Inspection.....	\$ 15.00
Turn on charge.....	<u>\$ 25.00</u>
	\$ 40.00

Watts Double Check Backflow Preventer No. 709 6"
Ser. # 251357
Max 175 Psi - 110° F .

PERMIT #152

Bill Andrade
+ Son