

SERVICE 33209

NEW BEDFORD WATER WORKS
APPLICATION FOR SERVICE AND METER

NEW BEDFORD

2-9-2006

I HEREBY ACKNOWLEDGE the receipt of a copy of the Regulations prescribed in the Ordinance of the City, for the use of Water, and I request that the water may be furnished through a

6 inch FIRE SUPPLY meter at 12 UNIT CONDO (SOUTHERLY)
ACUSHNET AVE N.Y. SASSAQUIN AVE

at such rates as may from time to time be established by the City.

I hereby agree to pay promptly the bill for the Service pipe laid down for my premises, and to pay all dues for water, and I agree to conform to the said Regulations and to all provisions of the Water Ordinances, until written notice is given by me or my agent to cut off the supply.

SERPER PERMIT # 2379/By: Albert Corga Sassaquin Village Associates LLC
P.137/L.29 915 Hathaway Rd. N.B.

TELEPHONE 508-965-2776

Service laid _____ Size and kind of pipe 4 D.I.

From ACUSHNET AVE _____ St.

Turned on _____ Meter Set _____

Reading _____ Location _____

Building rates _____ Paid _____

Cost of Service _____ Paid _____

Acushnet Ave., N x Sassaquin Ave. Ser # 33209

See Ser # 33212 for 8" controlling valve on Acushnet Ave.

Measures of 6" Gate Valve:

W x W line Bldg. (#4559) 9.0 ft.

N x N line Bldg. (#4559) 19.5 ft.

Chris Mendonza Co. installed 6" Fire Supply to

Condo on Lot 29

8" x 8" x 6" Tee

6" Gate Valve

6" DI Pipe

Inspection \$ 30.00

Turn on Charge \$ 30.00

\$ 60.00

work done MAY 23, 2006