

SERVICE 34059

reconnection

29451

NEW BEDFORD WATER WORKS

APPLICATION FOR SERVICE AND METER

NEW BEDFORD

10/24/20

10/24/19

I HEREBY ACKNOWLEDGE the receipt of a copy of the Regulations prescribed in the Ordinance of the City, for the use of Water, and I request that the water may be furnished through a

1" inch copper meter at

0 Fish Island

at such rates as may from time to time be established by the City.

I hereby agree to pay promptly the bill for the Service pipe laid down for my premises, and to pay all dues for water, and I agree to conform to the said Regulations and to all provisions of the Water Ordinances, until written notice is given by me or my agent to cut off the supply.

P. 160

Z. 4

~~Frank Corp.~~

Abm Marine

33 Echo Rd

Masphe 02649

TELEPHONE 995997

Service laid

Size and kind of pipe

From

* Meter pit + responsibility of owner

St.

Turned on

* Future Bldg use will require

Meter Set

Reading

abovement of meter pit

Location

Contractor: Frank Corp.

Building rates

* meter to be installed @ New

Paid

Cost of Service

chk # 1500

Bldg.

Paid

31-727

254003

✓

10-28-2019: inspection done by Manuel Rose
Bonded contractor, Frank Corp
Meter pit Box was installed.

DISPLAY PERMIT IN A CONSPICUOUS PLACE ON THE PREMISES



Commonwealth of Massachusetts

City of New Bedford

133 William Street New Bedford, MA 02740

WATER SERVICE PERMIT



Date: 11/18/2019

No. **W-19-27**

Permit Fee: \$500.00

Service Location: SS-60- FISH ISLAND

Owner Name: MIKUTOWICZ JOHN

Owner Phone #: (508) 995-997

Type of Occupancy: Industrial

Type of Work: Water - Domestic New 1"

Work Description: water service#34059
reconnection of 29451

P.60
L.4

0 Fish Island
meter pit responsibility of owner,
future bldg use will require abandonment of meter pit
meter to be installed at new bldg

Contractor

Name: _____ Certificate #: _____ Type of Business : _____

Address: _____ City/Town/State: _____ Phone #: _____

Type of Service _____ Pipe Size _____ Trench Length: **0.00**

Fire Service _____

Domestic Service _____

Estimated consumption of water

Estimated average daily consumption 0.00 gallons

Cross Connection? **No**

Estimated maximum day consumption 0.00 gallons

Right of Way? **No**

Are lawn sprinklers and/or lawn irrigation proposed on site? **No**

Meter Impact? **No**

Estimated fire flows required for the project site: 0.00

Street Opening Permit Required? **No**

Does the project require a fire suppression system? **No**

Call Phone: (781) 942-9077 For Inspection

"7 Fish Island"

- ▣ Ownership & Plot & Lot #
- ▣ install ^{in-line} backflow preventer before spigot.
- ▣ permit to have disclaimer that owner takes full responsibility of meter pit. City on responsible to south line of 20' wide easement.
- ▣ future building use will require abandon meter pit & install meter @ entry of building



