

W-21-21
SERVICE 34127

NEW BEDFORD WATER WORKS

APPLICATION FOR SERVICE AND METER

NEW BEDFORD 05-01-2021 to 05-01-2022

I HEREBY ACKNOWLEDGE the receipt of a copy of the Regulations prescribed in the Ordinance of the City, for the use of Water, and I request that the water may be furnished through a

1 inch Copper meter at South East corner of Spring St
P. 46 L. 85 and Seventh St

at such rates as may from time to time be established by the City.

I hereby agree to pay promptly the bill for the Service pipe laid down for my premises, and to pay all dues for water, and I agree to conform to the said Regulations and to all provisions of the Water Ordinances, until written notice is given by me or my agent to cut off the supply.

Park

ABOLITION
ROW

City of New Bedford Parks & Recreation, 81 Hillman St,

See attached for signature

New Bedford
MA

TELEPHONE 508-961-3015

Service laid W.C. Smith Size and kind of pipe 1" copper

From 8" water main on seventh street St.

Turned on Meter Set

Reading Location

Building rates Paid

Cost of Service \$ 0.00 Paid per engineering

31-727

S x s Line of Spring St	7.5'
N x N Line School St	211.0'
E x W Line Seventh St	16.0'

5-13-21: WC SMITH

8-10-21: Contractor WC SMITH

Inspector: Manuel Rose

Service done from curb stop inside

SERVICE 34127

NEW BEDFORD WATER WORKS
APPLICATION FOR SERVICE AND METER

NEW BEDFORD 05-01-2021 to 05-01-2022

I HEREBY ACKNOWLEDGE the receipt of a copy of the Regulations prescribed in the Ordinance of the City, for the use of Water, and I request that the water may be furnished through a

1 inch Copper meter at South East corner of Spring St
P. 46 L. 85 and Seventh St

at such rates as may from time to time be established by the City.

I hereby agree to pay promptly the bill for the Service pipe laid down for my premises, and to pay all dues for water, and I agree to conform to the said Regulations and to all provisions of the Water Ordinances, until written notice is given by me or my agent to cut off the supply.

park

City of New Bedford Parks & Recreation, RI Hillman St,
Ryan J. Ryan - JAM Corporation New Bedford
P.O. Box 60118
Worcester, MA 01606

TELEPHONE 508-961-3015

Service laid W.C. Smith Size and kind of pipe 1" copper

From 8" water main on seventh street St.

Turned on Meter Set

Reading Location

Building rates Paid

Cost of Service \$ 0.00 Paid per engineering

31-727



Department of Public Infrastructure

Jamie Ponte
Commissioner

Water
Wastewater
Highways
Engineering
Cemeteries
Park Maintenance
Forestry
Energy

CITY OF NEW BEDFORD

Jonathan F. Mitchell, Mayor

To Whom It May Concern:

City of New Bedford
Parks Recreation & Beaches
181 Hillman St Bld 3
New Bedford, Ma 02740, being
(Name) (Mailing Address)

Owner of property located at

Plot 46, Lot 85, hereby agree to allow JAM Corporation
(Name)
60 Canterbury St, Wrentham MA, to act on my behalf including affixing my
(Mailing Address) 01610

signature in securing permit for:

☐ Sewer/Drain Service Permits
☒ Water Service Permits
☐ Driveway Installation Permits
☒ Sidewalk Installation Permits

I further agree to conform to, and abide by, All City rules and ask regulations applicable to the permit (s) being applied for:

Name

Mary S. Raposa
Signature
New Bedford Parks Recreation & Beaches
181 Hillman St Bld 3, New Bedford, Ma 02740
Address

5-12-2021

Date

508-961-3015

Telephone Number

DISPLAY PERMIT IN A CONSPICUOUS PLACE ON THE PREMISES



Commonwealth of Massachusetts

City of New Bedford

133 William Street New Bedford, MA 02740

WATER SERVICE PERMIT



Date: 7/12/2021

No. **W-21-21**

Permit Fee: \$500.00

Service Location: 30 SEVENTH ST

Owner Name: ALLEN HOUSE ON 7TH ST LLC

Owner Phone #: (508) 961-3015

Type of Occupancy: Residential

Type of Work: Water - Domestic New 1"

Work Description: Water#34127
P.46 L.85

South East Corner x Spring St & Seventh St

1" COPPER
8" water main on Seventh Street

expires 05.01.2022
\$0 per engineering

Contractor

Name: Eric W. Smith

Certificate #: HE 039659

Type of Business: Hoisting

Address: 148 Westview Street

City/Town/State: New Bedford

MA

Phone #: (508) 995-

Type of Service

Pipe Size

Trench Length:

0.00

Fire Service

Domestic Service

Estimated consumption of water

Estimated average daily consumption 0.00 gallons

Estimated maximum day consumption 0.00 gallons

Are lawn sprinklers and/or lawn irrigation proposed on site? No

Estimated fire flows required for the project site: 0.00

Does the project require a fire suppression system? No

Required minimum static pressure for the proposed project site

Cross Connection? No

Right of Way? No

Meter Impact? No

Street Opening Permit Required? No

Call Phone: (781) 942-9077 For Inspection

DISPLAY PERMIT IN A CONSPICUOUS PLACE ON THE PREMISES



Commonwealth of Massachusetts

City of New Bedford

133 William Street New Bedford, MA 02740

WATER SERVICE PERMIT

0.00



GRANTED WITH THE USUAL CONDITIONS

Water

COMMISSIONER

Call Phone: (781) 942-9077 For Inspection

Amanda Jupin

From: Adam Hart
Sent: Tuesday, October 5, 2021 11:52 AM
To: Amanda Jupin
Subject: FW: [EXTERNAL] Abolition Row Park PSI Test & Water Chlorination and Sample Water Results
Attachments: JAM CORP 22 7TH ST. NEW BEDFORD MA. 9-27-21.pdf; JAM CORP. 9-27-21.pdf

34127

Good Afternoon Amanda,

Would you please attach these two PDFs to the permit for the water at Abolition Row Park.

Thank You!



Adam Hart, E.I.T.

Supervising Civil Engineer
City of New Bedford | Public Infrastructure, Engineering
1105 Shawmut Ave, New Bedford, MA 02746
508.979.1550 x 67332 | email: Adam.Hart@NewBedford-ma.gov

From: Ryan Wambach <ryan@jamcorpma.com>
Sent: Tuesday, October 5, 2021 9:16 AM
To: Heather Heimarck HLD <hheimarck@highmarklanddesign.com>; Barbara Conolly <barbara@gardensbybarbaraconolly.com>; Mary S. Rapoza <Mary.Rapoza@newbedford-ma.gov>; Valovia Costa <Valovia.Costa@newbedford-ma.gov>; Shawn Syde <Shawn.Syde@newbedford-ma.gov>; Adam Hart <Adam.Hart@newbedford-ma.gov>
Subject: [EXTERNAL] Abolition Row Park PSI Test & Water Chlorination and Sample Water Results

Good Morning Everyone,

Please see the attached test results for the PSI Test Taken and passed with no leaks, as well as the water sample test results after the line was chlorinated with passing results.

I will keep everyone updated on the installation of the electrical enclosure and the final electrical hookup when we get closer to November.

Thank you,

Ryan



Ryan Wambach
Project Manager, JAM Corporation

P: (508) 852-4119 | Fax: 508-459-0775 | ryan@jamcorpma.com

www.jamcorpma.com

P.O. Box 60118 | Worcester | MA | 01606-0118



CERTIFICATE OF ANALYSIS

Kevin Belasco
Baystate Winsupply
344 John Dietsch Blvd. #20
Attleboro Falls, MA 02763

Project Name: Drinking Water Jam Corp
Work Order Number: A110776
Date Received: 09/27/2021

Sampled By: Bill Robillard
Location: 22 Seventh St New Bedford MA 100Ft 1In Copper 1In Service End

Date Sampled: 9/27/21 11:30
Matrix: Drinking Water

RESULTS OF ANALYSIS

Parameter	Analytical Method	Date Analyzed	Units	Det. Limit*	MCL/ Rec Limit#	Result
Test Parameters				LAB-ID#: <u>A110776-01</u>		
Coliform, Total	1604	9/27/2021	CFU/100mL	1	Absent	Absent
E.coli	1604	9/27/2021	CFU/100mL	1	Absent	Absent

NA = Not Applicable
ND = Not Detected
< = Less Than
* = Detection Limit
Rec Limit# = Recommended Limit

Approved By: *Laurie H. Costa*

Work Order Narrative:

No unusual observations noted.

REVIEWED

By Nellie daCosta at 5:02 pm, Sep 30, 2021



Division of Thielsen Engineering

A1I0776



**422 West Grove Street
Middleboro, MA 02346
Phone: 508-946-2225
Fax: 508-946-3335
Lab I.D. #M-MA022**

LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT.

RW- REAGENT WATER
DW- DRINKING WATER
GW- GROUND WATER
SW- SURFACE WATER
SO- SOIL

MATRIX CODES

SE- SEDIMENT
SL- SLUDGE
HW- HAZARDOUS WASTE
WW- WASTE WATER
PW- POOL WATER

CONTAMINATION LEVEL

L- LOW
M- MEDIUM
H- HIGH
U- UNKNOWN

TURN AROUND TIME (TAT)
NORMAL (7-10 Buisness Days)

- * TAT begins when sample is received at testing facility.
- * TAT for samples received after 4p.m. will begin on the next business day.
- * All TAT's are subject to laboratory approval and customer consent.



Meter and Waterworks Services
95 Turnpike Street W. Bridgewater, MA 02379
(ph.) 866-983-8080 (fax) 508-583-2249

PRESSURE TEST REPORT

☐ Baystate ☐ Billerica ☐ Cape Cod ☐ Easton
☐ Warwick ☒ Westport ☐ Other: _____

Date:	9/27/2021	
Customer Name	JAM CORP.	
Job Location	22 7TH ST. NEW BEDFORD, MA.	
Water District	NEW BEDFORD WATER	
Testing Specifications	150	PSI
	2	# of Hours
Length, Size & Material	100', 1", K COPPER	
Static System Pressure	55	PSI
Test Results	PASS	
Test Conducted By	BILL ROBILLARD	
Witness	N/A	
Chlorination	YES	
Duration of Contact	24 HOURS	
Sample Taken By	BAYSTATE WINSUPPLY	
Results	PASS	
Certified by: President Baystate Winsupply	<i>Steve Vaccaro</i>	

