

APPLICATION No.: 1001

TAP CLEARED

LOCATION: 362 County St.OWNER: Julio BaldoMEASURES: 3/4" Copper May 13, 1872

E from E line County St. 41.4 ft.

N from S line Bedford St. 6.0 ft.

W from E line jog in house 6.6 ft.

Jan. 8, 1965 Service renewed from main to 4 ft. inside curb stop

12 ft. 3/4" cop. tubing

1 3/4" cop. to cop. stop fig 415

1 lb. wiping solder

1 5/8" reused corporation coupling

Tap reamed

Ingersoll -Rand Compressor: Warrenite

1 sidewalk cut: 5' x 2' Blacktop

Abraham

Breton

9/28/79: Franklin renewed service from the curb stop to the
property line.

7 ft.-3/4" copper

1-5/8" x 3/4" lead-cop. adapt.

1/5/12 - City crew repaired tap leak - Renewed water
service from main to a point 2 ft
2 ft = 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop
cplg comp, 1 - 5/8" x 3/4" Fig 413; Tap cleaned
Foreman: Frank Bento

DATE BEF. AFT. REMARKS

11/6/12 8.00 2012-010 4045

[illegible]

CHARGE OUTS

[illegible]