

APPLICATION No.: 10015

TAP CLEARED

LOCATION: 899 Rockdale Ave.

OWNER: Joseph C. DeMello

DATE BEF. AFT. REMARKS

1/30/80

Reamed

MEASURES: 3/4" L lead 10-15-1901
N from Milton 43.4 ft.
E from W line Rockdale 17.7 ft.
S from S line House 15.2 ft.
Tap measure N x Milton 40.3 ft.

July 26, 1971 Repaired service - torn up by Franklin
3 ft. of 3/4" copper tubing 2 wipe joints

1/30/80: Renewed from main to 10 ft. front of main.
10 ft. - 3/4" copper; 3/4" x 3/4" Fig. 413; 5/8" x 3/4"
lead-cop. adapt. XXS; -----

7/2/08 - West End Water Main Rehab Contract #4 - Perrina Const.
Renewed service from main to property line
23 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;
1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

[illegible]

CHARGE OUTS

[illegible]