


APPLICATION No.: 1013TAP CLEARED LOCATION: 14 So. SixthOWNER: D.J RealtyMEASURES: 3/4"

S from

W from E line

N from S line

Spring

Sixth

Body House

39.4 ft.

6.7 ft.

5.3 ft.

June 14, 1966 Renewed service from main to 3 ft. inside sidewalk.
23 ft. of 3/4" copper tubing 1 5/8" reused corporation coupling
1 3/4" cop. to cop. stop 1 lb.wiping solder

OCT 9 1979 Franklin renewed service from the curb stop to the
curb stop to prop. line.
8 ft.-3/4" copper
1-3/4" curb stop 1-Caldwell stop box
1-5/8" x 3/4" lead-cop. adapt.

Dec 12, 1995: Renewed from ^{curb stop} ~~main~~ to 4ft ins.prop line
Stock: 12 ft 3/4" copper tubing same curb stop
same Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

12/05/07 - Leak on ~~main~~ ⁼⁼⁼⁼⁼ Tightened couplings
Foreman: M. Rose ⁼⁼⁼⁼⁼

9/29/16: Service renewal from curb stop to meter,

JLC Contractor: P.Reynolds Inspector

DATE

BEF.

AFT.

REMARKS

12-12-96

955001077

Haw Elect

[illegible]

CHARGE OUTS

[illegible]