

APPLICATION No.: 10148

TAP CLEARED

LOCATION: 125 Reynolds

OWNER: ~~Hudneck~~ HUBECEK

MEASURES:

5/8"

W from Reynolds

31.5

N from S line Peckham

9.0

E from W line house

8.5

-----  
August 30, 1963 Renewed from main to 2 ft, inside curb stop  
12 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop  
1 5/8" reused corporation coupling  
-----

Sept. 22, 1977: Renewed from curb stop to inside cellar wall.  
13 ft.-3/4" copper (6 ft. inside); Caldwell stop box;  
-----

Sept. 23, 1977: Renewed from main to curb stop/ 8 ft.-3/4" copper;  
1-5/8" x 3/4" Fig. 413; tap reamed; 3/4" curb stop;

DATE

BEF.

AFT.

REMARKS

8-30-63

Reamed

9-23-77

"

6-1-1902

[illegible]

## CHARGE OUTS

[illegible]