

SERVICE

Application No. 10288

St. & No. 91 Bullard, N.S., W. of Acush. Ave.
 Size Pipe Kind Pipe Laid
 5/8" H lead Oct. 11, 1894
 W from W. line Acush. Ave. St. 141.0 ft.
 S from N line Bullard St. 8.5 ft.
 E from E line house St. 36. ft.

INACTIVE Sept. 1978

City

33 ft. Earth

32 ft. Pipe

Taker

46 ft. Earth

47 1/2 ft. Pipe

16 30

12-22-52, service leak, renewed 1 ft. on street side of property line using 1 ft. 3/4" cop. tubing. 2# wiping solder.

10-6-54, ser. leak, renewed 9 ft. on street side of meter using 9 ft. 3/4" cop. tubing type K, soft. 1# wiping solder. Bill No. 48280-\$17.83.

11-30-1955, ser. leak, renewed from a point 9 ft. from meter to a point 24 ft. from meter (this ser. goes across a driveway & underneath service that supplied No. 87 Bullard St. and to the stop box of #91) used 15 ft. 3/4" cop. tubing.

Stock supplied & installed by owner's plumber.

9/8/66, renewed from 1/2 ft. outside curb stop to property line; 8 1/2 ft. of 3/4" copper tubing.

9/19/78 discontinued; plugged at main while cement lining. ~~Material abandoned in ground.~~