

LOCATION:

APPLICATION No.:

TAP CLEARED

OWNER:

31-313

MEASURES:

Feb 10, 1903

W from County St 19.1'

N from S line Nelson St 8.7'

W from E line house 13.6'

1" COPPER SERVICE

8/6/2020:Lead service line replacement program
phase 1. TYPED BY: [illegible]

phase 1, TYPE CU, Diameter 1inch, Water Pressure 100

Distance from main to curb stop 6'

Distance curb stop to meter 10'

Distance from curb face to curb stop 1.8'

Depth of service 4.0'

Total length of new pipe installed 4'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve replaced:NO Size 3/4"

Remarks: 1- 3/4" union installed where shown

DATE _____

REF

AFT

REMARKS

12/1/86: Tap reamed

6/24/1998

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

