

APPLICATION No.: 10320

TAP CLEARED

LOCATION: 101-103 & 103 1/2 South St.

DATE

BEF.

AFT.

REMARKS

OWNER: Hyman Parkin

P. 36 - L. 295

8/21/95: tap reamed

953-403-491

MEASURES:

5/8"

H lead

Mar. 11, 1903

W from

County St.

230.5 ft.

S from N line

South St.

9.7 ft.

W from Eline

house

13.8 ft.

Aug 21, 1995:

Renewed from main to prop line

Stock: 31ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x5/8 lead-cop adapt. xs

1- 3/4 x 5/8 Fig 413 =====

1" Copper Service

08/30/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curbstop (Ft) N/A

Distance curb stop to meter (ft) 24

Distance from curb face to curb stop (ft) 2

Depth of service (ft) 4

Total length of new pipe installed (ft) 24

Curb stop replaced: no Corporation replaced: no

Ball valve replaced: yes size 1"

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
7-20-70		5/8	Rock Mag	20771165					

