

APPLICATION No.: 10323 5/8" H lead

TAP CLEARED

LOCATION: 107-9 Ashley Blvd.

OWNER: Carlton Bradshaw

MEASURES: 5/8"

H lead

Mar. 13, 1903

. S from N line

Beetle

26.2 ft.

E from W line

Ashley Blvd.

8.9 ft.

S from N line

House

14.2 ft.

3/1/79: Renewed 6" outside to 1.6 ft. inside curb stop. 2 ft.-3/4"
copper; 3/4" curb stop; 2-5/8" x 3/4" lead-cop. adapt. XXS;
Caldwell stop box;

DATE

BEF.

AFT.

REMARKS

Note: if there are any more leaks
on this service it should be
repaired from main to prop. line
because of ducts & ledge.

METER HISTORY

[illegible]

CHARGE OUTS