

APPLICATION No.: 10466
LOCATION: 83 Trinity St. DUPLICATE
OWNER: James A. Sherman etux

MEASURES: 3/4" Lead

E x line Shawmut Ave. 191.6 ft.
S x N line Trinity St. 7.0 ft.
W x E line house 6.9 ft.

APR 23 1982 -- Tilcon renewed service from the main to the property line. 25.0 ft. - 3/4" copper; 3/4" curb stop; stop box; 1" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS;

4/29/86: Renewed from main to a point 3.0 ft. Stock: 3.0ft.
3/4" copper tubing 1 - 3/4 x 3/4 cop to cop cplg. comp.
1 - 3/4" Fig. 413

NOTE: THIS LADY SAYS SHE HAS HAD POOR PRESSURE SINCE WARREN BROS. RENEWED HER SERVICE FROM MAIN TO PROP. IN APRIL 1982(4yrs.) SHE WAITED 4 YRS. TO COMPLAIN ABOUT POOR PRESSURE. THE TAP WAS REAMED AGAIN BUT IT WAS CLEARED SO WHO KNOWS WHERE THE PROBLEM IS.

5/22/11 - City crew cleaned the tap - owner was complaining of low pressure. Pressure increased from 30 lbs to 40 lbs - Paul Monteiro checked inside house - owner has internal problem. Foreman: Bill Days

TAP CLEARED T863 099

DATE BEF. AFT. REMARKS

4/29/86: TAP REAMED

5/19/11 11:50

2611-2104617

[illegible]

CHARGE OUTS

[illegible]