

APPLICATION No.: 10492

TAP CLEARED

LOCATION: 64 Tallman

OWNER: Georgiana Esa

07-03-1903

MEASURES: 5/8"

E from

Acushnet Ave.

134.1 ft.

N from S line

Tallman

8.0 ft.

W from E line

House

0.7 ft.

10/13/78: Franklin Const. renewed service from the main
to the property line. 64 ft. - 3/4" copper; 3/4" curb stop;
Caldwell stop box; 5/8" x 3/4" Fig. 413; 5/8" x 3/4"
lead-cop. adapt. XXS -----

11/24/09 - Percy was sent to check water in cellar -
leak found under foundation. Owner to call for estimate
for City to do renewal -----

12/4/09 - Owner hired DPI to renew water service from
curb stop to meter

16 ft - 3/4" copper tubing; 1 - Caldwell stop box

Foreman: Danny Perry

DATE

BEF.

AFT.

REMARKS

12/2/09 1:45

2009-4804472

[illegible]