

APPLICATION No.: 10573

TAP CLEARED 85-35-3025

LOCATION: 72 Crapo St.

OWNER: Gilbert Cabral

MEASURES: $\frac{1}{2}$ " H lead Sept. 11, 1903.

S from Thompson St. 198.3 ft.

W from E line Crapo St. 6.8 ft.

S from N line house 10.6 ft.

9/3/85: Renewed from $\frac{1}{2}$ ' outside curb stop to a point 4 ft.

Stock: 4ft. 3/4" copper tubing 1 3/4" curb stop

1 Caldwell stop box 2 3/4x5/8 lead to cop adapt. xxs.

000000	000000	000000	000000	000000	000000
000000	000000	000000	000000	000000	000000

100000	100000	100000	100000	100000
100000	100000	100000	100000	100000

July 17, 1995: CRAPO ST RECONSTRUCTION

Todesca Corp renewed serv. from main to prop line

Cont. supplied all stock & will maintain trench

Stock: 26 ft 3/4" copper tubing 1-3/4" curb stop

1- stop box 1-3/4x5/8 lead-cop adapt.xs 1-3/4x5/8 Fig 413

Insp. Dennis Monty

ADDITIONAL MEASURES:

S x N line house 6.0ft

N x S line house 16.0 ft

✓ NOTE: copper goes over sewer 2½ft of cover copper insulated

Feb. 23, 1999 Dug street - leak inside. No work done.

9-2-99 Renewed from 3 ft. inside curb stop to cellar.
(16 ft. ins. prop. line) Stock: 16 ft. - 3/4" Copper
tubing, 1 - Caldwell Stop Box, 1 - 3/4"x3/4" cop to cop
cplg., comp.

BRADBURY-WARING, INC.

[illegible]

CHARGE OUTS

[illegible]