

APPLICATION No.: 10625

TAP CLEARED

LOCATION: 111-13 Bonney St.

OWNER: Arthur Silva

MEASURES: 5/8"

H lead ~~lead~~ **COPPER** Nov. 4, 1903

W from

Bonney St.

46.8 ft.

N from S line

Fair St.

9.2 ft.

E from W line

house

9.4 ft.

April 29, 1970 Renewed 1/2 ft. outside curb stop to inside cellar.

18 ft. - 3/4" copper tubing; (8 ft. inside); 1 - 3/4" Mueller curb stop; 1 wipe joint;

- - -

Sept 19, 1997: Renewed from main to a point 1.0ft

Stock: 1.0ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 5/8 Fig 413 =====

10.09.2018 - Lead Service Line REplacement Program

Contractor: P. Gioioso and Sons

Type: CU, Diameter (in) 1, Water Pressure (PSI) 100

Distance from main to curb stop (ft) 12, distance curb stop to meter (ft) n/a, distance from curb face to curb stop (ft)

2.5, Depth of service (ft) 4.5, total length of new pip

nstalled (ft) 12.

Curb stop replaced: Yes, Size 1", Corporation REplaced:

Yes, Size 1", Ball Valve Furnished: NO size n/a

DATE

BEF.

AFT.

REMARKS

9/19/97

973807531

9/19/97: tap reamed

10/5/2000 6000 410 7638

[illegible]

\_\_\_\_\_

