

APPLICATION No.: 10641

TAP CLEARED 82310557

LOCATION: 115 117 Bonney St

OWNER:

31-313

MEASURES:

10.04.2018 - Lead Service Line Replacement Program

Contractor: P. Gioioso and sons

Type: CU, Diameter (in) 1, Water pressure (PSI) 100

Distance from main to curb stop (ft) 8, Distance curb

stop to meter (ft) 19, Distance from curb face to curb

stop (ft) 1, Depth of Service (ft) 4.0, Total length

of new pipe installed (ft) 22

Curb stop replaced: Yes, Size 1", Corporation replaced:

Yes, Size 1" Ball Valve Furnished: Yes, Size 1"

S from Fair St 67.5 ft

E from W line Bonney St 6.9 ft

N from S line House 11.2 ft

November 20, 1903

DATE

BEF.

AFT.

REMARKS

Aug 24, 1982 Ream

Jun 31, 1995 Ream

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

