

APPLICATION No.: 10669

TAP CLEARED ✓

LOCATION: Manomet

140 RIVERSIDE AVE

OWNER:

10"

MEASURES: E from

Riverside Ave.

245.0 ft.

N from S line

Manomet

30.5 ft.

E from E line

waste house

51.2 ft.

F

I

R

E

SUPPLY

Jan. 5, 2000 Frank Corp. Environmental repaired a small hole punched in main bybackhoe on private 10" fire supply.

Installed 1 - 10" Smith Blair #227 Clamp Cplg. 10"W.

Location of cplg:

N x n line boiler room

6.0 ft.

W x W line bldg.

20.0 ft.

