

APPLICATION No.: 10671

TAP CLEARED

7

LOCATION: 213 No. Water

OWNER: N.B. Warer Works

MEASURES: 6"

S from	North	204.0 ft.
E from W	Water	8.5 ft.
N from N	bldg.	15.0 ft.
E	fence.	12.3 ft.

shut off at Gate valve 6/1/72

February 27, 1964 Repaired 5/8" service that is connected to
Fire Supply inside the Water Dept. yard.

Renewed from 6" outside the curb stop to 9 1/2 ft. inside the
curb stop.

10 ft. of 3/4" copper tubing	1 3/4" copper to copper stop
1 3/4" copper coupling A-1525	1 3/4" copper elbow ^o

INACTIVE SER

[illegible]

CHARGE OUTS

[illegible]