

APPLICATION No.: 10704 3/4"

## TAP CLEARED

LOCATION: 691 Cottage St.

OWNER: Guido Coucci

MEASURES: 3/4"

S from

Durfee

109.0 ft.

E from Wline

Cottage

9.3 ft.

S from N line

House

3.9 ft.

11/19/77: Leak over tap. Renewed from main to 4 ft. front of main.  
4 ft.-3/4" copper; 3/4" x 3/4" Figure 413; 5/8" x 3/4" lead to cop.  
adapt. XXS;

Street reconstruction May 21, 1997

Renewed from main to prop line

Stock: 18ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

same 3/4x3/4 Fig 413

=====

DATE

BEF.

AFT.

REMARKS

11/19/77

Reamed

tap reamed

5/21/97

[illegible]

# CHARGE OUTS