

APPLICATION No.: 10746

## TAP CLEARED

LOCATION: 163 Rockland St.

OWNER: George Frates

MEASURES: 5/8" H lead May 23, 1904

W from Briggs St. 86.0 ft.

S from N line Rockland St. 9.6 ft.

E from W line house 10.9 ft.

8/7/08 - Percy went to check water leak - leak not bad - 10 ft punch  
service is under floor before meter, City to renew from main to  
curb stop

-----  
11/19/08 - City hired by owner to renew service from main to inside  
cellar

34 ft -3/4" copper tubing; 1 -3/4" curb stop box; 1 Caldwell stop  
box; 1 -5/8" x 3/4" Fig. 413; Tap reamed. Foreman: Danny Perry  
-----

DATE

BEF.

AFT.

REMARKS

11-19-08 8:00

2008-4703836

11-19-08

Tap reamed

[illegible]

## CHARGE OUTS

[illegible]