

APPLICATION No.: 10790

TAP CLEARED

LOCATION: 112-14 Cove St.

OWNER: Thomas C. Archer

DATE

BEF.

AFT.

REMARKS

10/25/75

Reamed

MEASURES: 1/2"

H lead

July 6, 1904

E from

Morton's Ct.

~~20.4~~ ft. 17.0 ft.

N from S line

Cove St.

~~19.8~~ ft. 9.0 ft.

E from W line

house

5.2 ft.

December 6, 1974 Renewed from 6" outside curb stop to property line.

10 ft. - 3/4" Copper tubing

3/4" Curb Stop

Caldwell Stop Box

2- 5/8" x 3/4" lead to copper Adapt. XS

Cannot reach owner to renew into cellar - Owner lives in Rochester.

Oct. 25, 1975 Renewed from the main to outside curb stop
8 1/2 ft. - 3/4" Copper tubing 3/4" Copper cplg.
5/8" x 3/4" Fig. 413

6/28/79: Renewed from curbstop to inside cellar. 14 ft. -
3/4" copper (Supplied by Owner)

Aug. 8, 1983 J.F. Kennedy Hwy. Proj. Renewed from 16" main to curb stop.

1-3/4" Mueller tap

22 ft. - 3/4" copper tubing

METER HISTORY

[illegible]

CHARGE OUTS