

TAP CLEARED

LOCATION: 172 Merrimac

OWNER: H.J. Ackerman

MEASURES: $3/4''$

E from	Chestnut	70.0 ft.
N from S line	Merrimac	9.1 ft.
E from W line	House	7.9 ft.

April 14, 1969 Renewed from the main to a point 3 ft. from
the main.

3 ft. - 3/4" Copper tubing 1" x 3/4" Fig. 413
1 wipe joint

3/2/79: Renewed 6" outside curb stop to 4.6 ft. inside. 5 ft.-3/4" copper; 2-5/8" x 3/4" lead-cop. adapt. XXS; 3/4" curb stop; Caldwell stop box;
- - - - -

3/22/79: Renewed from corp. tap to a point 3 ft. from tap
3 ft.-3/4" copper; 5/8" x 3/4" lead-cop. adapt. XXS; 3/4"
x 1" Fig. 413;

1/19/94: Core ^{curb stop} was leaking--tighten curb stop

9/27/94: REnewed from main to ins.cellar (8ft ins.prop line)
Stock: 26ft 3/4" copper tubing 1-3/4" curb stop
same Caldwell stop box 1-3/4x3/4 Fig 413

DATE _____

BEF.

AFT.

REMARKS

4/14/69

Reamed

3/22/79

Reamed

1-19-	54
-------	----

940300948

9-27
91

943901929

9/27/94: tap reamed

[illegible]

CHARGE OUTS

[illegible]