

APPLICATION No.: 10824

TAP CLEARED

LOCATION: 13 Bay St.

OWNER: Manuel Viera

MEASURES: 3/4" <sup>lead</sup>  
Gopper Aug. 5, 1904

W from Dartmouth St. 126.4 ft.

S from N line Bay St. 7.9 ft.

W from E line house 12.5 ft.

Feb. 20, 1945 Leak near tap. 3' - 5/8" H. lead pipe;  
 June 27, 1949 New from tap to 1 ft. inside curb stop.  
 20 ft. - 3/4" copper tubing;

12/9/92: Renewed from main to a point 5ft

Renewed from 1ft outside curb stop to a point 4ft

Stock: 10ft 3/4" copper tubing same curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

2-3/4x3/4 cop-cop cplg.comp 1-5ft from main 1-lft outside curb stop

1-3/4" corp tap 1-6x3/4 service saddle

8/23/12 - City crew renewed water service from main to meter

28 ft -3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell stop box; 1 - 5/8" x 3/4" Fig 413; Tap reamed.

Foreman: Ronnie Aguiar

DATE

BEF.

AFT.

REMARKS

12/9/92: Tap reamed

9256-1121

Clear Elect.

8/23/12

2012-340-7982

## METER HISTORY

## CHARGE OUTS

[illegible]