

138

APPLICATION No.: 10851

TAP CLEARED

LOCATION: B 8 MaxfieldOWNER: John D. MartinMEASURES: $5/8$ "

E from

Walden

64.2 ft.

N from S line

Maxfield

7.2 ft.

E from W line

House

6.4 ft.

12/23/77: Renewed 6" outside curbstop to inside cellar wall. 12 ft. $-3/4$ " copper (5 ft. ins.); $3/4$ " curbstop; $5/8$ " x $3/4$ " lead to cop. adapt. XS; Caldwell stop box;

7/16/79: Franklin renewed service from the main to the curb stop. 8 ft. $-3/4$ " copper; $5/8$ " x $3/4$ " Fig. 413;

Inside leak underground leak 3/29/89 Dante

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]