

#137

APPLICATION No.: 10943

TAP CLEARED 9035-0040

LOCATION: ~~135-7~~ Rockland St. (cor)

OWNER: Antonio M. Felipe

DATE

BEF.

AFT.

REMARKS

8/27/90: TAP REAMED

MEASURES: 5/8" H lead Dec. 1, 1904

N from Rockland St. 57.5 ft.

E from W line Orchard St. 8.6 ft.

S from N line house 3.9 ft.

8/27/90: Renewed from main to prop line  
Stock" 20 ft. 3/4" copper tubing 1-3/4" curb stop  
1-Caldwell stop box 1- 3/4x5/8 lead to cop adapt. xxs  
1- 3/4x5/8 Fig. 413

1" Copper Service

10/24/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 14

Distance from curb face to curb stop (ft) 2.5

Depth of service (ft) 5

Total length of new pipe installed (ft) 14

Curb stop replaced: No Corporation replaced: No

Ball valve replaced: Yes size 1"

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
1-23-64		5/8	Hersey F	710778					

# CHARGE OUTS

