

APPLICATION No.: 10962

TAP CLEARED

LOCATION: 13 Harmony St

DATE

BEF.

AFT.

REMARKS

OWNER:

09/29/93 Ream

31-313

MEASURES: March 24, 1905

N X Brock Ave 67.3 ft

E X W Line Harmony St 9.5 ft

S X N Line House 10.4 ft

1" Copper Service

Lead Service Line Replacement Program 03/27/2019

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water Pressure 100

Distance from main to curb stop (ft) 8

Distance from curb stop to meter (ft) 19.5

Distance from curb face to stop stop (ft) 1.0

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 19.5

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1 lf outside
curb stop

[illegible]

CHARGE OUTS

