

103 on House
Service Killed

APPLICATION No.: 10992 3/4"

TAP CLEARED

LOCATION: 101 Clark St. Cor. Myrtle St.

OWNER: A.C. Roderiques

MEASURES: 3/4"

W from
S from N line
on W line

Myrtle
Clark
Building

17.0 ft.
9.0 ft.

August 25, 1975 Renewed from the main to 5 ft. from the main.

5 ft. - 3/4" Copper tubing 1 wipe joint
1" x 3/4" Fig. 413
- - -

April 20, 1976 Renewed from the main to the property line.

32 ft. - 3/4" Copper tubing 3/4" Curb Stop
Caldwell Stop Box 3/4" x 3/4" Fig. 413
5/8" x 3/4" lead to copper adaptor XXS
- - -

4/12/2011 RJ Canessa Killed this service at the Tap.
Bldg to be demolished. Inspected by Percy.

DATE

BEF.

AFT.

REMARKS

8/25/75

Reamed

4/20/76

Reamed

METER HISTORY

CHARGE OUTS

[illegible]