

APPLICATION No.: 11014

TAP CLEARED

LOCATION: 62 Vine

OWNER: J. Gregory

MEASURES: S from Mt. Verono 366.6 ft.
 W from E Vine 7.0 ft.
 N from S house- 2.0 ft.

 February 3, 1969 Renewed from 6" outside curb stop to the property line.

10 $\frac{1}{2}$ ft. of 3/4" copper tubing 1 3/4" Mueller curb stop
 2 wipe joints

 October 6, 1950 Leak at tap.

3 ft. of 3/4" copper tubing- 1 1" I.P.Fem.x 3/4" cop.cplg.

APR 1 1982 - Tilcon renewed service from the main to the property line. 27.0 ft.-3/4" copper; 3/4" curb stop; stop box; 5/8" x 3/4" lead-cop. adapt. XXS;

July-1986: Renewed from prop line to inside cellar--by owner all stock supplied by owner. 1 - 3/4x3/4 cop to cop cplg. comp at prop line. - 11 ft. 3/4" copper tubing.

November 20, 2002: Renewed from main to a point 2 ft. in front of the main; 2 ft. - 3/4" copper tubing; 1-3/4" x 3/4" cop. to cop. cplg. comp; tap reamed

=====

DATE

BEF.

AFT.

REMARKS

11/19/02

3:45 PM

2002-

11/20/02

1 PM

2002-470-5306

[illegible]

CHARGE OUTS

[illegible]