

LOCATION: 117 Bullard St.

OWNER: Raymond Jansen

DATE

BEF.

AFT.

REMARKS

8/11/55

Reamed

MEASURES: 3/4"

E from Ashley Blvd. 75.7 ft.

S from N line Bullard 9.0 ft.

W from E line House 16.4 ft.

Change over 3/4" from curb to caller 4-16-69

Aug. 27, 45 Leak near tap new 7 ft. in from tap.
 7 ft. - 5/8" H. lead pipe.

Aug. 11, 1955 Renewed from tap to 1ft. inside curb
 stop.

22 ft. - 3/4" copper tubing; 1-3/4" cop to cop stop,
 fig. 415; 1-3/4" x 3/4" coupling fig. 413; 1# solder;
 Tap reamed.

July 26, 1958 Renewed from a point 8 inches inside
 property line to meter inside building.
 14 ft. - 3/4" copper tubing.

April 16, 1969 Renewed from the curb stop to meter
 inside the cellar.

24 ft. - 3/4" copper tubing (14' inside);

7/18/05 Replaced and reset Curb Stop Box.

Caldwell Stop Box.

METER HISTORY

CHARGE OUTS

[illegible]