

LOCATION: 73 Independent St

APPLICATION No.: 11141

TAP CLEARED

OWNER:

31-313

MEASURES: Aug 7, 1905

E X Crapo St	92.8 ft
--------------	---------

S X N Line Independent St	9.8 ft
---------------------------	--------

E X W Line House	14.0 ft
------------------	---------

1" Copper Service

11/29/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 23.5

Distance curb stop to meter (ft) 17

Distance from curb stop to curb face (ft) 1.5

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 23.5

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no size 3/4"

Remarks: 1-3/4" union installed 1LF outside curb stop

[illegible]