

APPLICATION No.: 11213

TAP CLEARED

LOCATION: 17 Holly

OWNER: R Auddette

MEASURES:

5/8"

E from

S from N line

W from E line

Front

Holly

house

272.7 ft.

9.2 ft.

12.0 ft.

9/18/78: Renewed from main to 2 ft. front of main.

2 ft.-3/4" copper; 5/8" x 3/4" lead to cop. adapt. XS;

5/8" x 3/4" Fig. 413; - - -

10/18/78: Franklin Const. renewed service from the main

to the property line. 32 ft.-3/4" copper; 5/8" x 3/4"

Fig. 413; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4"

lead-cop. adapt. XXS

11/8/85: Renewed from main to a point 2.0 ft.

Stock: 2.0 ft. - 3/4" copper tubing      1 - 3/4x3/4 cop to cop cplg.

comp. 1 - 3/4 x 5/8 Fig. 413 1 - 5/8" corporation tap.

(Contractor broke tap off main--fixed same. Water service is showing. Service is over storm drain.

=====

10/29/14 W.C. Smith renewed service from curb stop to cellar

[illegible]

## CHARGE OUTS

[illegible]