

APPLICATION No.: 11220TAP CLEARED 84620413LOCATION: 132 ThompsonOWNER: Annie EnosMEASURES: 5/8"

W from	Briggs	77.6 ft.
N from S line	Thompson	9.5 ft.
E from W line	House	14.5 ft.

Jan. 18, 1984 - Renewed from $\frac{1}{2}$ ft. outside curb stop
to a point 3.5 ft. inside curb stop.

4.0 ft. - $\frac{3}{4}$ " copper tubing

1 - $\frac{3}{4}$ " curb stop 1 stop box

2 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to copper adaptors XXS

5/9/84 Poor pressure - checked by Pitta - shut off not working.
Owner Russell Pittsley

10/21/88 Plumber called poor pressure - informed him of above.

11/2/88: REnewed from main to a point 1ft.

Stock: 1ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt. xxs

1 - $\frac{3}{4}$ x $\frac{5}{8}$ Fig.413

=====

12/16/03 Renewed from main to inside cellar. (8 ft. inside property
line). Stock: 24 ft. $\frac{3}{4}$ " copper tubing; $\frac{3}{4}$ " curb stop; Caldwell

stop box; $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413 Tap reamed

DATE

BEF.

AFT.

REMARKS

11/2/88: TAP REAMED

12/16/03 Tap reamed

8844-2593

[illegible]

CHARGE OUTS

[illegible]