

APPLICATION No.: 11234

TAP CLEARED

8413-0801

LOCATION: 87 Maple Cor. Chancery

OWNER: Andrew B. Chase Jr.

MEASURES: 5/8"

W from

Chancery

11.5 ft.

S from N line-

Maple

9.0 ft.

W from E line

House

4.1 ft.

DATE

BEF.

AFT.

REMARKS

3/27/84

REAMED

974104939

10/8/97: tap reamed

6-2000 Tap reamed

March 2, 1961 Renewed from 1/2 ft. outside curb stop to
1 ft. inside curb stop.

1 1/2 ft. - 3/4" Copper tubing 3/4" copper stop
2# wiping solder

- - -

March 27, 1984 - Renewed from main to a point 6.0 ft.
from the main.

6.0 ft. - 3/4" copper tubing

1 - 5/8" x 3/4" lead to copper adaptor XS

1 - 5/8" x 3/4" Fig. 413

- - - - -

Oct 8, 1997: Renewed from main to 2ft inside curb stop

Stock: 26ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box 1-3/4x5/8 lead-cop adapt.xs 2ft ins.curb stop

1- 3/4x5/8 Fig 413

=====

6-2000 Renewed from main to property line. Stock: 18ft. - 3/4"
Copper tubing, 1 - 3/4" Curb Stop, 1 - 3/4" Caldwell Stop Box,
1-5/8"x3/4" lead to cop.adapt.XXS, 1 - 3/4" Corporation tap.
Zenone Const. to maintain cut.

[illegible]

CHARGE OUTS

[illegible]