

APPLICATION No.: 11302

TAP CLEARED



LOCATION: No. Front (Fire Supply)

DATE

BEF.

AFT.

REMARKS

OWNER: Tauton &amp; N.B. Copper Co.

MEASURES:

8"

FIRE SUPPLY

N/G

S from Logan 402.0

S from S line Office 23.0

W from E line Front St. Fence 8.4

W from E line Front St. 5.0

May 11, 1977 repaired leaking joint on fire supply.  
5# lead wool.

- - -

Dec. 5, 1980 Repaired leak by repacking 10" gate.  
2 - 5/8" x 6" Rods & nuts 6" x 1/4" packing

Sept. 1989 Relocated ser. from old abandoned 8" main to new 8" ductile main as part of new sewer & drain project:  
Renewed from new 8" x 8" x 8" tee easterly to an 8" 22½° bend tied to existing 8" service - approx. 3 ft. E x main. see sketch

July 6, 1992 During Belleville Ave. Sewer project - gioioso Const. cut out a section of 8" fire supply in order to blast ledge & dig for new sewer pipt. REinstalled with:

8.1 ft. pc. of 8" ductile pipe from the 8" x 8" tee to a point 27 ft. E x W line No. Front St.  
1 - 8" Ford cast cplg.

01.18.2023 - Service cut and capped at main located inside of private property.  
Contractor Bill Milka Inspector Percy Reynolds

## METER HISTORY

[illegible]

## CHARGE OUTS



SHT # 2 OF 2

SEPT. 1989

DRY WEATHER ABATEMENT FACILITIES PROTECT  
WATERMAIN RELOCATION - NO. FRONT ST. BETW. LOGAN & WAMISUTTA

③ &amp; ④

4" & 8" WATER SERVICES TO REVERE COPPER & BRASS

