

APPLICATION No.: 11312

## TAP CLEARED

LOCATION: 141 Hemlock Street

OWNER:

31-313

MEASURES: 3/4" copper

3/1/17 renewed main to c/s

1 ft 3/4" curb stop valve

1 ft cast iron curb stop boxes

13 ft 3/4" copper tubing

1 ft 5/8" corp adapter

lead worker - ronald aguiar dpi

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 11312

TAP CLEARED

LOCATION: 141 Hemlock St.

OWNER: Joseph Costa

MEASURES: 3/4" Copper Feb. 27, 1906

S from Swift St. = 10.5 ft.

E from W line Hemlock St. 8.5 ft.

S from N line House 9.0 ft.

Aug. 1, 1955 Renewed from a point 1/2 ft. outside curb  
stop to inside cellar

12 ft. of 3/4" copper tubing type K, soft

1-3/4" copper stop fig, 415

1 wiped joint

1 sidewalk cut: 4' x 2' cement

Frasier M.

Madeira

Feb. 5, 1979 Renewed from main to a point 2 ft. from main.

2 ft. - 3/4" copper tubing 1 - 5/8" x 3/4" fig. 413

1 - 5/8" x 3/4" lead to cop adapt. XXS

-----  
Check Rent Water - Took sample - clear 2/21/91

Olga gave nest remover lady 1st floor

Told lady to call C Kennedy Quittias to take regular sample 3/8/91



[illegible]

## CHARGE OUTS

[illegible]