

APPLICATION No.: 11366

TAP CLEARED

LOCATION: 415 Orchard St

OWNER:

31-313

MEASURES: April 16, 1906
N X Thompson St 73.8 ft
E X W Line Orchard St 8.5 ft
N X S Line House 12.5
1" Copper Service
10/24/2018 Lead Service Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 90
Distance from main to curb sop (Ft) 8
Distance from curb stop to meter (ft) 19.8
Distance from curb face to curb stop (ft) 1.5
Depth of service (ft) 4
Total length of new pipe installed (Ft) 19.8
Curb stop replaced: no size 3/4
Corporation replaced: no size 3/4
Ball valve replaced: yes size 1"
Remarks: 3/4-1 union installed 1.0 lf outside
curb stop

DATE

BEF.

AFT.

REMARKS

[illegible]