

11395

1

TAP CLEARED

OWNER:

31-313

237.7 ft

S X N Line Tinkham St

9.0 ft

## EXW Line House

 $0.2 \text{ ft}$ 

5/24/2018 1" Copper Service

# Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter 1in, Water pressure 70

Distance from main to curb stop (Ft) 24

Distance from curb stop to meter (ft) 20

Distance from curb face to curb stop (ft) 2

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 47

Public 24 ft , Private 23 ft

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: Yes size 1"

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

7/14/66 Ream

[illegible]