APPLICATION No.:	APPLICATION No.:11427			TAP CLEARED			
LOCATION: 17 Social St		DATE	BEF.	AFT.	REMARKS		
OWNER:							
MEASURES. June 18,1906 W X E Line Harmony St S X N Line Social st E X N Line House 1" Copper Service 4/18/2019 Lead Service Line Replacemen Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure Distance from main to curb stop (ft) 2 Distance curb stop to meter (ft) 17.3 Distance from curb face to curb stop (Total length of new pipe installed (ft Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: Yes size 1" Depth of Lunce (44)4	100 3.6 ft) 1.7						

