

APPLICATION No.: 11429

## TAP CLEARED

LOCATION: 22-24 Mc Gurk St.

OWNER: Roger R. Savaria

MEASURES: 5/8" H lead June 26, 1906

S from Social St. 52.4 ft.

W from E line      McGurk St.      9.0 ft.

N from S line      House      13.3 ft.

July 26, 1973 Renewed from the main to a point  $3\frac{1}{2}$  ft.  
inside curb stop.

26½ ft. - 3/4" Copper tubing      3/4" Hays curb stop  
5/8" x 3/4" Fig. 413 cplg.

9/22/68 Percy observed leak outside foundation, owner mailed Bonded Contractor list. *ms*

10/07/08 - Farland Enterprise renewed service from curb stop into cellar. Owner charged \$100 (\$30 shut-off & \$70 for inspection)  
Inspected by Percy Reynolds. NOTE: 5/8" meter returned  
New Measurements:

S from S line	Social St	52.5
W from E line	McGurk St	8.0
N from S line	House	13.3
S from N line	House	16.0
W from W line	House	16.0
Main to Property	Line	34.0
Pipe inside property		12.0

*Continued*  
BRADBURY-WARING, INC.

BRADBURY-WARING, INC.

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

7/26/73

2/8/09 8:00

Reamed

2009-0801526

[illegible]

## CHARGE OUTS



11429

APPLICATION No.:

LOCATION: 22 - 24 McGurk St

OWNER:

31-313

MEASURES:

2/18/09 - City crew found leak at curb stop on 2/16/09 & replaced

1 ft - 3/4" copper tubing & curb stop on 2/18/09

Foreman: Danny Perry

-----

## TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 190460

TAP CLEARED



LOCATION: Rear of 24 McGurk

OWNER: \_\_\_\_\_

MEASURES: 5/8"

Conn. of service App. 11429 made by taker

INACTIVE SER

DATE

BEF.

AFT.

REMARKS

[illegible]