

APPLICATION No.: 11442

TAP CLEARED

LOCATION: 357 Davis St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

12/5/90 Ream

MEASURES:

E X Church St 132.8 ft

S X N line Davis St 9.4 ft

E X W line House 7.0 ft

1" Copper Service

06/12/2018 - Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter 1in Water pressure 70

Distance from main to curb stop (ft) 24.3

Distance from curb stop to meter (ft) 16.8

Distance from curb face to curb stop (ft) 2.4

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 41.1

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball Valve furnished: yes size 1"

[illegible]

CHARGE OUTS

