

APPLICATION No.: 11479

## TAP CLEARED

LOCATION: 336 Nash Rd.

OWNER: Eugene Spirlet

MEASURES: 5/8"

E from	Church	114.0 ft.
N from S line	Nash Rd.	9.0 ft.
E from W line	House	8.8 ft.

July 15, 1957 Renewed from main to a point 3 ft. inside curb stop  
12 ft. of 3/4" copper tubing 1-3/4" copper stop, fig. 413  
1 lb. wiping solder - - -

Dec 14, 1995: Renewed from curb stop to a point 3.5 ft  
Stock: 3.5 ft 3/4" copper tubing 1- Caldwell stop box  
1- 3/4 x 5/8 lead-cop adapt.xs

1" Copper Service

=====

05/09/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type Cu, Diameter 1in, Water pressure 68

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 16.5

Distance from curbface to curb stop (ft) 1.5

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 19.5

Curb stop replaced: NO, Corporation repalced: NO

Ball valve replaced: YES size 1"

Remarks: 3.0 ft WHIP

DATE

BEF.

AFT.

REMARKS

6/15/57

Reamed

12-14-95

955002676

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
5-25-39		5/8	Hersey D	637184					

## CHARGE OUTS

